

J.R. HENDERSON LABS, INC.  
 123 SEAMAN AVENUE  
 BEACHWOOD, NJ 08722-2817  
 Certified Lab. I.D #15083

WATER SYSTEM NAME: E. J. SCHOOL

200 SOUTH BARNEGAT AVE, SURF CITY, NJ 08008

Meghan-609-494-8851 X012

SAMPLE DATE: 6/1/16

9 Non-Compliance Samples

PARAMETER: LEAD

Testing Site: E.J. SCHOOL

CONTACT-DAVID YATES

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
Faculty Lounge sink	6/1/16 06:30	LEAD	200.9	6/3/16 10:18	0.006
Nurse's Office sink	6/1/16 06:31	LEAD	200.9	6/3/16 10:22	0.010
Main Office sink	6/1/16 06:32	LEAD	200.9	6/3/16 10:35	0.009
GYM Water Cooler	6/1/16 06:35	LEAD	200.9	6/3/16 10:39	0.001
Kitchen Sink #1	6/1/16 06:36	LEAD	200.9	6/3/16 10:47	0.018
Kitchen Sink #2	6/1/16 06:37	LEAD	200.9	6/3/16 10:55	0.024
Kitchen Sink #3	6/1/16 06:38	LEAD	200.9	6/3/16 11:03	<0.001
Main Hall West Water Cooler	6/1/16 06:40	LEAD	200.9	6/3/16 11:16	<0.001
Main Hall East Water Cooler	6/1/16 06:41	LEAD	200.9	6/3/16 11:55	<0.001

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water.

J.R. HENDERSON LABS, INC.  
123 SEAMAN AVENUE  
BEACHWOOD, NJ 08722-2817  
Certified Lab. I.D #15083

WATER SYSTEM NAME: E. J. SCHOOL

200 SOUTH BARNEGAT AVE, SURF CITY, NJ 08008

Meghan-609-494-8851 X012

SAMPLE DATE: 6/14/16

2 Non-Compliance Samples

PARAMETER: LEAD

Testing Site: E.J. SCHOOL

CONTACT-DAVID YATES

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
Kitchen Sink #1	6/14/16 08:30	LEAD	200.9	6/15/16 12:56	0.002
Kitchen Sink #2	6/14/16 08:31	LEAD	200.9	6/15/16 13:03	0.012

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water.