

J.R. HENDERSON LABS, INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 Certified Lab. I.D #15083

WATER SYSTEM NAME: LONG BEACH ISLAND CONSOLIDATED SCHOOL DISTRICT

201 20TH ST., SHIP BOTTOM, NJ 08008

Meghan-609-494-8851.X012

SAMPLE DATE: 6/1/16

14 Non-Compliance Samples

PARAMETER: LEAD

Testing Site: LBICSD

CONTACT-DAVID YATES

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
Faculty Lounge sink	6/1/16 07:00	LEAD	200.9	6/3/16 12:00	0.001
Nurse's Office sink	6/1/16 07:01	LEAD	200.9	6/3/16 12:04	0.001
Boro Office Water Cooler	6/1/16 07:02	LEAD	200.9	6/3/16 12:08	<0.001
5-6 Hall Water Cooler	6/1/16 07:04	LEAD	200.9	6/3/16 12:13	<0.001
Main Office Water Cooler	6/1/16 07:05	LEAD	200.9	6/3/16 12:34	<0.001
3-4 Hall Water Cooler	6/1/16 07:06	LEAD	200.9	6/3/16 12:38	0.003
Guidance Office Water Cooler	6/1/16 07:07	LEAD	200.9	6/3/16 12:46	0.012
Kitchen Sink #1	6/1/16 07:10	LEAD	200.9	6/3/16 12:50	<0.001
Kitchen Sink #2	6/1/16 07:11	LEAD	200.9	6/3/16 12:55	0.022
Kitchen Sink #3	6/1/16 07:12	LEAD	200.9	6/3/16 13:34	0.025
Kitchen Sink #4	6/1/16 07:13	LEAD	200.9	6/3/16 13:59	0.006
Kitchen Sink #5	6/1/16 07:14	LEAD	200.9	6/3/16 14:03	0.006
Science Hall Water Cooler	6/1/16 07:16	LEAD	200.9	6/3/16 14:07	<0.001
Board office Sink	6/1/16 07:20	LEAD	200.9	6/3/16 14:12	0.009

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water.

J.R. HENDERSON LABS, INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 Certified Lab. I.D #15083

WATER SYSTEM NAME: LONG BEACH ISLAND CONSOLIDATED SCHOOL DISTRICT

201 20TH ST., SHIP BOTTOM, NJ 08008

Meghan-609-494-8851 X012

SAMPLE DATE: 6/14/16

2 Non-Compliance Samples

PARAMETER: LEAD

Testing Site: LBICSD

CONTACT-DAVID YATES

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
Kitchen Sink #2	6/14/16 08:15	LEAD	200.9	6/15/16 13:08	0.001
Kitchen Sink #3	6/14/16 07:16	LEAD	200.9	6/15/16 13:12	0.002

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water.